

## MANUFACTURER DECLARATION

We hereby declare under our sole responsibility that the following products

<b>T-, L-, 935-, ZZ-Series, TX6 <sup>1)</sup></b>	<b>TIH, TX3-, TI-Series, TX7, LIV <sup>1)</sup></b>	<b>TIH-, TX3- <sup>1)</sup> - FLR</b> (for R290)
---	---	---

1) followed by number indicates the capacity and the type of refrigerant

comply with the basic requirements of following **EU Directives**:

- Pressure Equipment Directive 2014/68/EU**

Fluid Group 2 according to PED <sup>2)</sup>	Fluid Group 1 according to PED <sup>2)</sup>
DN ≤ 32	DN ≤ 25
Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.	Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.
Conformity assessment: not applicable	Conformity assessment: not applicable

2) for the full list of refrigerants see Operating Instructions

Applied harmonized standards:

EN 378-2: 2016	Refrigerating systems and heat pumps - Safety and environmental requirements. Parts 2: Design, construction, testing, marking and documentation.
EN 12284: 2003	Refrigerating systems and heat pumps – Valves – Requirements, testing and marking.

Signed for and on behalf of Emerson Climate Technologies GmbH:



Matthew Irons (Vice-President Engineering)  
Aachen, June 01, 2020